

L. Roberto Lomas P.E.

233 W. Main St  
Danville, VA 24541  
434-688-0609  
rlomas@lrlomaspe.com

# Engineering Evaluation Report

Report No.: 511864A

**Manufacturer:** VuSafe Industries, LLC  
350 Kidds Hill Road  
Hyannis, MA 02601



**Product Line:** Storm Shutter Type D

**Compliance:**

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(d). The product listed herein complies with requirements of the current Florida Building Code.

**Supporting Technical Documentation:**

1. Approval document: drawing number 08-01262, Revision B, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Report No.: ETC-07-1089-19072.2 signed and sealed by Joseph Labora Doldan P.E.  
ETC Laboratories, Rochester, New York  
ASTM E330-02 Design Pressure: ±60psf  
ASTM E1886-05 and ASTM E1996-05  
ASTM E1886/ E1996 Large Missile Impact, Level D, Wind Zone 4  
ASTM E1886/ E1996 Cyclic Load Test, ±60.0psf design pressure
3. Anchor calculations, report number 511864-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

**Limitations and Conditions of use:**

- Maximum design pressure: ±60.0psf
- Maximum Panel Height: 86"
- This product is not rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions.

**Installation:** Units must be installed in accordance with approval document, 08-01262, Revision B.

**Certification of Independence:** Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

